



To: Mountain Regional Water Administrative Control Board Members
From: Brian Davenport
Date: January 2026
Re: Operations Department Update

OVERVIEW OF PAST MONTH

1. In the past month we had 3 main line repairs and 1 valve repair. The repairs were in Summit Park and Newpark areas. (see photo of Summit Park on Matterhorn Drive)
2. For 2025 staff repaired a total of 18 main line breaks, 17 lateral repairs and 6 valve/hydrant repairs for the year. We serviced 1368 fire hydrants out of 1593. Well above our goal of 531 per year. All Stagecoach PRV's were rebuilt (6 sites, 12 valves) and 10 of the 77 PRV's (24 sites) in the Colony were rebuilt.
3. The Jail House well was pulled. Waiting on pump and motor to arrive. We had another well in the Blackhawk area fail. Waiting for it to be pulled.
4. Lost Canyon staff is currently working on installing pump 1 at Lost Canyon as part of the upgrade project. Electrical will be the next phase.
5. Ordered Well 15B and Nugget's pumps and motors. Waiting on arrival and will then install, should be soon.

FOCUS FOR NEXT MONTH:

1. Snow removal
2. Lost Canyon staff moving into the Silver Creek site and organizing it for inventory supplies.
3. Working on a strategy to fix a leak under one of our pump stations in the Preserve area. Will work on the repair this month.

