



To: Mountain Regional Water Administrative Control Board Members
From: Brian Davenport
Date: May 2026
Re: Operations Department Update

OVERVIEW OF PAST MONTH

1. In the past month we have had one main line repair. It was in Summit Park on Matterhorn Drive. Crews fixed 3 service lines and upgraded the meter pits. Repairs were in Silver Springs and Spring Creek. Staff installed a new hydrant in Park West Village.(see photo)
2. 3 of the 4 seasonals are on board and working on hydrants in the Promontory area.
3. Atkinson Well 2 pump and motor is installed (see photo) along with the Jailhouse well and the Nugget well. We will get them in the loop after we do some sampling next week.
4. Sun Peak well 3 electrical should be completed next week. We will work on getting that well back in the loop.
5. Lost Canyon staff working on Old Ranch pump repairs and new shop.

FOCUS FOR NEXT MONTH:

1. Installation of the Atkinson Well 2 ASR piping.
2. Lost Canyon staff working on Old Ranch pump station pump upgrade and new Lost Canyon shop building installation.
3. Old Stone House flow control station upgrades for the Northridge area.
4. Work on getting Sun Peak Well 3 back online.
5. Lost Canyon pump 1 booster upgrades



