



To: Mountain Regional Water Administrative Control Board Members  
From: Brian Davenport  
Date: June 2026  
Re: Operations Department Update

\*\*\*\*\*

### **OVERVIEW OF PAST MONTH**

1. In the past month we had no main line breaks. Pretty unusual but we will take it. Staff upgraded 2 meters in the Spring Creek area where we moved inside meters to the outside and installed meter pits. We will be doing this periodically throughout the summer.
2. All of the seasonals are on board and working on hydrants in the Promontory area. They have inspected over 400 hydrants so far. Our goal is to do a third of our approximately 1600 hydrants per year.
3. All of our wells have been repaired and are up and running in time for peak season.
4. Staff has been working on upgrades on a flow control vault in the Spring Creek area to push more water up into the Northridge area.
5. Lost Canyon staff have been working on the new shop and transformer upgrades. (See photo)

### **FOCUS FOR NEXT MONTH:**

1. Installation of the Atkinson Well 2 ASR piping ongoing.
2. Lost canyon staff will continue working on the new Lost Canyon shop building installation and transformer upgrades
3. Old Stone House flow control station upgrades for the Northridge area.
4. Lost Canyon pump 1 upgrades

